

TECHNICAL CHECKLIST

(To be submitted in bidder's letter head with authorized signature)

| Sl.No | Material Code | Qty | UOM | Material Long text | Bidder's acceptance to material description [yes/no] | If "no" deviation to material long text to be provided below |
|-------|---------------|------|-----|--|--|--|
| 1 | 82072990270 | 800 | EA | TECHNICAL SPECIFICATION : ELECTRICAL FEED THROUGH TERMINAL BLOCK, SISE: 2.5 SQMM MATERIAL: POLYMIDE GOVERNING STANDARD: IEC 60947-7-1 SIZE: 2.5 SQ MM CROSS SECTION: 0.5 SQMM TO 4.0 SQMM TIGHTENING TORQE:0.5 NM NOMINAL CURRENT:24A NOMINAL VOLTAGE: 800 V RATED SURGE VOLTAGE: 8KV OPERATING TEMPERATURE: - 60 TO 80 DEG CENTIGRADE MOUNTING: DIN RAIL TYPE OF CONTACT CONNECTION: SINGLE SCREW TYPE: LOW CONTACT RESISTANCE SUITABLE FOR PIN TYPE LUGS COLOUR: GREY/BLACK/KHAKI | | |
| 2 | 82072990410 | 1200 | EA | TECHNICAL SPECIFICATION : ELECTRICAL FEED THROUGH TERMINAL BLOCK, SISE: 6.0 SQMM MATERIAL: POLYMIDE GOVERNING STANDARD: IEC 60947-7-1 SIZE: 6.0 SQ MM CROSS SECTION: 1.5 SQMM TO 6.0 SQMM TIGHTENING TORQE:1.5 NM NOMINAL CURRENT:50 A NOMINAL VOLTAGE: 800 V RATED SURGE VOLTAGE: 8KV OPERATING TEMPERATURE: - 60 TO 80 DEG CENTIGRADE MOUNTING: DIN RAIL TYPE OF CONTACT CONNECTION: SINGLE SCREW TYPE: LOW CONTACT RESISTANCE SUITABLE FOR PIN TYPE LUGS COLOUR: GREY/BLACK/KHAKI | | |
| 3 | 82072990650 | 600 | EA | TECHNICAL SPECIFICATION : ELECTRICAL FEED THROUGH TERMINAL BLOCK, SISE: 10.0 SQMM MATERIAL: POLYMIDE | | |

| | | | | | | |
|---|-------------|-----|----|--|--|--|
| | | | | <p>GOVERNING STANDARD: IEC 60947-7-1</p> <p>SIZE: 10.0 SQ MM</p> <p>CROSS SECTION: 1.5 SQMM TO 16.0 SQMM</p> <p>TIGHTENING TORQE:1.4 NM</p> <p>NOMINAL CURRENT:57 A</p> <p>NOMINAL VOLTAGE: 800 V</p> <p>RATED SURGE VOLTAGE: 8KV</p> <p>OPERATING TEMPERATURE: - 60 TO 80 DEG CENTIGRADE</p> <p>MOUNTING: DIN RAIL</p> <p>TYPE OF CONTACT CONNECTION: SINGLE SCREW</p> <p>TYPE: LOW CONTACT RESISTANCE</p> <p>SUITABLE FOR PIN TYPE LUGS</p> <p>COLOUR: GREY/BLACK/KHAKI</p> | | |
| 4 | 82072990720 | 600 | EA | <p>TECHNICAL SPECIFICATION :</p> <p>ELECTRICAL FEED THROUGH TERMINAL BLOCK, SISE: 16.0 SQMM</p> <p>MATERIAL: POLYMIDE</p> <p>GOVERNING STANDARD: IEC 60947-7-1</p> <p>SIZE: 16.0 SQ MM</p> <p>CROSS SECTION: 6.0 SQMM TO 16.0 SQMM</p> <p>TIGHTENING TORQE:1.2 NM</p> <p>NOMINAL CURRENT: 76 A</p> <p>NOMINAL VOLTAGE: 1000 V</p> <p>RATED SURGE VOLTAGE: 8KV</p> <p>OPERATING TEMPERATURE: - 60 TO 80 DEG CENTIGRADE</p> <p>MOUNTING: DIN RAIL</p> <p>TYPE OF CONTACT CONNECTION: SINGLE SCREW</p> <p>TYPE: LOW CONTACT RESISTANCE</p> <p>SUITABLE FOR PIN TYPE LUGS</p> <p>COLOUR: GREY/BLACK/KHAKI</p> | | |

NOTE :

1. THE REPUTED MAKE/BRANDS ONLY ACCEPTABLE. UN-BRAMNDED MAKE SHALL NOT BE ACCEPTABLE.
2. IN CASE OF DEALERS/DISTRIBUTORS/RESELLERS(NON-OEM VENDORS) PARTICIPATING IN THE TENDER, THE AUTHORISATION LETTER FROM THE O.E.M WITH DETAIL SEAL,SIGN, ADRESS AND CONTACT NUMBER MUST BE ATTACHED IN THE TENDER,FAILING WHICH THE OFFER SHALL BE SUMMARILY REJECTED.
3. THE SPECIFICATIONS/NAME OF MANUFACTURER MUST BE CONFIRMED IN THE OFFER, FAILING WHICH THE OFFER IS LIABLE FOR REJECTION.
4. THE RELAVANT CATALOGUES MUST BE ATTACHED IN THE OFFER.
5. TEST CERTIFICATE FROM THE MANUFACTURER'S, GOVT LAB, NABL ACCREDITATED LAB AND GUARANTEE CERTIFICATE FOR EACH ITEM/EACH LOT SHALL BE SUBMITTED ALONG WITH SUPPLY OF MATERIAL.