

BUYER SPECIFICATION DOCUMENT

TECHNICAL SPECIFICATION

SR.NO	Item code	Material Description	Qty.	Bidder Confirmation (Please put 'V' in front of confirmation)
1	300153012	<p>VALVE POSITIONER SPARE FOR 02HIC-8 AS PER FOLLOWING SPECIFICATIONS:</p> <ol style="list-style-type: none">SERVICE: PROCESS GAS VENTMODEL NO.: DVC 6200 (DOUBLE ACTING) (P/N: DVC-3793-4348375), WITHMAKE: FISHER (EMERSON PROCESS),VALVE SR.NO.:IA76626ACTUATOR TYPE: 585C/130 8 INCHCAM CHARACTERISTICS: LINEARCERTIFICATION: ATEX/IS <p>NOTE:</p> <ol style="list-style-type: none">VENDOR TO ENSURE THAT THE OFFERED PART SHALL BE INTERCHANGEABLE AND IDENTICAL TO THE EXISTING PART IN THE ORIGINAL EQUIPMENT.VENDOR SHALL SUBMIT INTERCHANGEABILITY CERTIFICATE ALONG WITH THE SUPPLY. <p>OFFERED MAKE: _____</p> <p>HSN CODE: _____</p>	1 NO	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed
2	300153009	<p>05LIC-7A VALVE SPARE TRIM SET CONSISTING OF PLUG, STEM, CAGE, SEAT RING, GASKET SET, REPAIR KIT (SOFT GOODS - VALVE) AS PER FOLLOWING SPECIFICATIONS :</p> <ol style="list-style-type: none">SERVICE: V-502 NH3 LEVEL,MAKE: FISHER (EMERSON PROCESS MANAGEMENT CHENNAI PRIVATE LIMITED),MODEL: 667 ED, SIZE: 3 INCH 300#,VALVE SR. NO.: GB489611PART NO.S: PLUG/STEM,M-FLUTE - 2U8687X0032 CAGE - 2U740348932 SEAT RING - 2U856246052 GASKET SET-RGASKETX162 KIT,REPAIR - RPACKX00012 <p>NOTE:</p> <ol style="list-style-type: none">VENDOR TO ENSURE THAT THE OFFERED PART SHALL BE INTERCHANGEABLE AND IDENTICAL TO THE EXISTING PART	1 ST	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed

You are requested to submit Technical specification annexure and Technical specification documents **with signed and stamped.**

		<p>IN THE ORIGINAL EQUIPMENT. 2. VENDOR SHALL SUBMIT INTERCHANGEABILITY CERTIFICATE ALONG WITH THE SUPPLY.</p> <p>OFFERED MAKE: _____</p> <p>HSN CODE: _____</p>		
3	300153007	<p>05LIC-1 VALVE SPARE TRIM SET CONSISTING OF PLUG, STEM, PISTON RING, GASKET SET, REPAIR KIT (SOFT GOODS - VALVE) AS PER FOLLOWING SPECIFICATIONS: 1. SERVICE: E-505 NH3 LEVEL, 2. MAKE: FISHER (EMERSON PROCESS MANAGEMENT CHENNAI PRIVATE LIMITED), 3. MODEL: 667 ED, SIZE: 4 INCH 300#, 4. VALVE SR. NO.: GB489609 5. PART NO.S: PLUG/STEM, BAL - 11A5344X022 RING,PISTON - 1U2392X0022 GASKET SET- RGASKETX212 KIT,REPAIR - RPACKX00112</p> <p>NOTE: 1. VENDOR TO ENSURE THAT THE OFFERED PART SHALL BE INTERCHANGEABLE AND IDENTICAL TO THE EXISTING PART IN THE ORIGINAL EQUIPMENT. 2. VENDOR SHALL SUBMIT INTERCHANGEABILITY CERTIFICATE ALONG WITH THE SUPPLY.</p> <p>OFFERED MAKE: _____</p> <p>HSN CODE: _____</p>	1 ST	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed
4	300153013	<p>VALVE POSITIONER SPARE FOR 03LIC-11A/B AS PER FOLLOWING SPECIFICATIONS: 1. SERVICE: BEN. ABS. C-302 LEVEL 2. MODEL NO.: DVC 6200 / HART COMMUNICATING (P/N: DVC-3793-4348375), WITH A) MOUNTING KIT FULL (GG04418X012) B) FEEDBACK MAGNET ASSEMBLY /ARRAY (ROTARY STEM) (GE38154X012) 3. MAKE: FISHER (EMERSON PROCESS MANAGEMENT CHENNAI PRIVATE LIMITED), 4. VALVE SR.NO.: IA12667 5. ACTUATOR TYPE: 1052/ SIZE 70 6. CAM CHARACTERISTICS: ROTARY (ROTATION 0-90 DEG)</p> <p>NOTE: 1. VENDOR TO ENSURE THAT THE OFFERED PART SHALL BE INTERCHANGEABLE AND IDENTICAL TO THE EXISTING PART IN THE ORIGINAL EQUIPMENT. 2. VENDOR SHALL SUBMIT INTERCHANGEABILITY CERTIFICATE ALONG WITH THE SUPPLY.</p>	1 NO	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed

You are requested to submit Technical specification annexure and Technical specification documents **with signed and stamped.**

		OFFERED MAKE: _____ HSN CODE: _____		
5	300153010	02HIC-1 VALVE SPARE TRIM SET CONSISTING OF PLUG, STEM, SEAT RING, PISTON RING, CAGE AS PER FOLLOWING SPECIFICATIONS: 1. SERVICE: PRCESS GAS TO E-201 2. MAKE: FISHER (EMERSON PROCESS MANAGEMENT CHENNAI PRIVATE LIMITED), 3. MODEL: 667 ED, SIZE: 3 INCH 600#, 4. VALVE SR. NO.: GB491259 5. PART NO.S: PLUG/STEM,BAL - 11A5338X512 SEAT RING - 1U222839102 RING,PISTON - 1U2342X0012 CAGE,LINER - 2U741848932 NOTE: 1. VENDOR TO ENSURE THAT THE OFFERED PART SHALL BE INTERCHANGEABLE AND IDENTICAL TO THE EXISTING PART IN THE ORIGINAL EQUIPMENT. 2. VENDOR SHALL SUBMIT INTERCHANGEABILITY CERTIFICATE ALONG WITH THE SUPPLY. OFFERED MAKE: _____ HSN CODE: _____	1 ST	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed
6	300153014	05LIC-11A VALVE SPARE BODY WITH INTERNALS (TRIM) AS PER FOLLOWING SPECIFICATIONS: 1. SERVICE: V-510 NH3 LEVEL 2. MAKE: FISHER (EMERSON PROCESS MANAGEMENT CHENNAI PRIVATE LIMITED), 3. MODEL: 667 ES, SIZE: 2 INCH 600 RF, 4. VALVE SR. NO.:GB 489612 5. FOR ACTUATOR MODEL: 667 SIZE 40 NOTE: 1. VENDOR TO ENSURE THAT THE OFFERED PART SHALL BE INTERCHANGEABLE AND IDENTICAL TO THE EXISTING PART IN THE ORIGINAL EQUIPMENT. 2. VENDOR SHALL SUBMIT INTERCHANGEABILITY CERTIFICATE ALONG WITH THE SUPPLY. OFFERED MAKE: _____ HSN CODE: _____	1 NO	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed
7	300153015	05LIC-11B VALVE SPARE BODY WITH INTERNALS (TRIM) AS PER FOLLOWING SPECIFICATIONS: 1. SERVICE: V-510 NH3 LEVEL	2 NO	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed

You are requested to submit Technical specification annexure and Technical specification documents **with signed and stamped**.

		<p>2. MAKE: FISHER (EMERSON PROCESS MANAGEMENT CHENNAI PRIVATE LIMITED),</p> <p>3. MODEL: 667 EZ, SIZE: 1 INCH 600 RF,</p> <p>4. VALVE SR. NO.: GB 491244</p> <p>5. FOR ACTUATOR MODEL: 667 SIZE 30</p> <p>NOTE:</p> <p>1. VENDOR TO ENSURE THAT THE OFFERED PART SHALL BE INTERCHANGEABLE AND IDENTICAL TO THE EXISTING PART IN THE ORIGINAL EQUIPMENT.</p> <p>2. VENDOR SHALL SUBMIT INTERCHANGEABILITY CERTIFICATE ALONG WITH THE SUPPLY.</p> <p>OFFERED MAKE: _____</p> <p>HSN CODE: _____</p>		
8	300153016	<p>VEE BALL SPARE FOR 03LIC-11A/B VALVE AS PER FOLLOWING SPECIFICATIONS:</p> <p>1. SERVICE: BEN. ABS. C-302 LEVEL</p> <p>2. MAKE: FISHER (EMERSON PROCESS MANAGEMENT CHENNAI PRIVATE LIMITED),</p> <p>3. VALVE SR.NO.: IA12667 AND IA48883</p> <p>4. SIZE: 6 INCH X 300# RF , TYPE : V300</p> <p>5. ACTUATOR TYPE: 1052/ SIZE 70</p> <p>NOTE:</p> <p>1. VENDOR TO ENSURE THAT THE OFFERED PART SHALL BE INTERCHANGEABLE AND IDENTICAL TO THE EXISTING PART IN THE ORIGINAL EQUIPMENT.</p> <p>2. VENDOR SHALL SUBMIT INTERCHANGEABILITY CERTIFICATE ALONG WITH THE SUPPLY.</p> <p>OFFERED MAKE: _____</p> <p>HSN CODE: _____</p>	1 NO	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed
9	300099688	<p>03 LIC-11 A OR B CONTROL VALVE SPARE REPAIR KIT V 150.200 & 300 SEALS RV150XHDC42 FOR AMMONIA-V</p> <p>OFFERED MAKE: _____</p> <p>HSN CODE: _____</p>	2 NO	<input type="checkbox"/> Agreed <input type="checkbox"/> Disagreed

Sr. No.	INSTRUCTION FOR BIDDERS	
1	Delivery Period	Delivery period of material shall be 36 weeks from the date of PO.
2	Guarantee/Wa	Vendor shall give guarantee/warranty for a period of 18 months from the date of

You are requested to submit Technical specification annexure and Technical specification documents **with signed and stamped.**

	rrantee Clause	supply or 12 months from the date of commissioning, whichever is earlier.
3	Instruction for Bidder	<ul style="list-style-type: none"> • Bidder has to submit signed and stamped copy of technical specification document. • Bidder shall submit completely filled, signed, stamped and scanned copies of all annexures attached in ATC documents.

You are requested to submit Technical specification annexure and Technical specification documents **with signed and stamped.**