

TECHNICAL PARAMETER SHEET

Following information's are to be provided by Technical Department along with MBs or Indents:

1. **Delivery Schedule:** Within 30 days.
2. **Guarantee/ Warrantee Clause:** 18 Months from Date of Supply or 12 Months from date of Installation, whichever is earlier.
3. **Performance Guarantee Clause:** As per NIT.
4. **Inspection Clause:** Inspection shall be done by SO (E&M), Orient Area or his authorized representative.
5. **Technical Parameter:** ABC make Electrical Spare.

Sl. No.	Material	Short Text	Manufacturer Part No.	Unit of Measure	Quantity
1.	6100005074	HT BOLT FOR FRONT COVER	CB100D11	EA	60
2.	6100005075	HT BOLT FOR TOP COVER	CB100D11A	EA	60
3.	6100005076	HT BOLT FOR CABLE BOX	CB100D11B	EA	30
4.	6100005085	SENSITIVE CBT FOR E/L RELAY 750 MA	CB100D2MA	EA	1
5.	6100005088	CURRENT TRANSFORMER FOR OVERLOAD	CB100D3	EA	3
6.	6100005106	SENSITIVE EARTH LEAKAGE RELAY UPTO 750MA	CB100C3MA	EA	1
7.	6100005138	HT BOLT FOR TOP COVER	CB200D11A	EA	50
8.	6100005142	HT BOLT FOR FRONT COVER	CB200D11	EA	50
9.	6100005155	BUSH INSULATOR FOR OUTGOING INTERLOCKING	CB200D21A	EA	9
10.	6100005156	SENSITIVE CBT FOR EL RELAY 750MA	CB200D2MA	EA	1
11.	6100005178	HT BOLT FOR CABLE BOX	CB200D11B	EA	20
12.	6100005180	BUSH INSULATOR FOR THROUGH GOING/INCOMIN	CB200D21	EA	9
13.	6100005191	EARTH LEAKAGE RELAY 750 MA	CB200C3MA	EA	1
14.	6100005266	BUSH INSULATOR FOR THROUGH GOING /INCOM	CB300D21	EA	6
15.	6100005267	BUSH INSULATOR FOR OUTGOING / INTERCONNE	CB300D21A	EA	6
16.	6100005298	INTERLOCKING PLUNGER WITH SPRING	CB200D24	EA	2
17.	6100005300	INTERLOCKING PLUNGER WITH SPRING	CB300D24	EA	2

Signature

5

18.	6100005388	HT ALLEN BOLT FOR FRONT COVER	CB300D11	EA	50
19.	6100005389	HT ALLEN BOLT FOR TOP COVER	CB300D11A	EA	50
20.	6100005390	HT BOLT FOR CABLE BOX	CB300D11B	EA	50
21.	6100010837	NEUTRAL RESISTOR	SDPA00017	EA	5
22.	6100010843	SENSITIVE EARTH LEAKAGE RELAY UPTO 750MA	SDPA0019MA	EA	1
23.	6100010870	FRONT COVER BOLT	SDPA0010	EA	50
24.	6100010871	TOP COVER BOLT	SDPA0011	EA	50
25.	6100010882	HRC FUSE BASE WITH CARRIER	SDPA00013	EA	7
26.	6100010885	HRC FUSE	SDPA00016	EA	20
27.	6100010886	RESISTANCE FOR PILOT RELAY	SDPA00017A	EA	4
28.	6100010887	TEST/RESET MICRO SWITCH	SDPA00018	EA	7
29.	6100010891	HT BOLT FOR TERMINAL BOX	SDPA0014	EA	50
30.	6100010899	SENSITIVE CBT FOR 750 MA EARTH LEAKAGE R	SDPA0019AMA	EA	1
31.	6100010901	HT BOLT FOR PLUG & SOCKET	SDPA0016	EA	10
32.	6100010910	PILOT RELAY	SDPA00012B	EA	4
33.	6100015854	HT BOLT FOR TOP COVER	FG133	EA	110
34.	6100016111	SENSITIVE CBT FOR EARTH LEAKAGE RELAY 75	FG116MA	EA	11
35.	6100016113	SENSITIVE EARTH LEAKAGE RELAY UPTO 750MA	FG115MA	EA	11
36.	6100016113	SENSITIVE EARTH LEAKAGE RELAY UPTO 750MA	FG115MA	EA	1
37.	6100016135	HT BOLT FOR TERMINAL BOX	FG134	EA	60
38.	6100016136	HT BOLT FOR FRONT COVER	FG132	EA	60
39.	6100016142	PILOT RELAY	FG120	EA	13
40.	6100016143	AUXILIARY TRANSFORMER (150VA)	FG119A	EA	5
41.	6100029069	MAIN CONTACTOR KIT FOR 90-150 HP	FDB102B2	EA	1
42.	6100029073	SENSITIVE EARTH LEAKAGE RELAY 750MA	FDB114MA	EA	2
43.	6100029074	AUXILLARY CONTACTOR	FDB142	EA	7
44.	6100029079	START/STOP MICRO SWITCH	FDB122	EA	11
45.	6100032254	TEST / RESET SPINDLE WITH FLAPPER	FDB124	EA	2

Handwritten signature

4

46.	6100032255	CT FOR OVERLOAD	FDB119	EA	3
47.	6100032261	CT FOR AMMETER	FDB120	EA	3
48.	6100033486	MAIN CONTACTOR, 50A	SDPA000141AN	EA	2
49.	6100034051	MAIN CONTACTOR COIL FOR 90-150 HP	FDB102B1	EA	1
50.	6100034052	MAIN CONTACTOR 90-150 HP	FDB102B	EA	2
51.	6100034055	AUXILIARY TRANSFORMER 250 VA	FDB117B	EA	2
52.	6100038943	TEST MICROSWITCH	CB100C5	EA	3
53.	6100040177	PILOT RELAY	FDB131	EA	13
54.	6100040606	OCTAL PLUG BASE	FDB132	EA	23
55.	6100040607	HT BOLT FOR TERMINAL BOX	FDB130	EA	50
56.	6100040608	HT BOLT FOR TOP COVER	FDB129	EA	50
57.	6100040609	HT BOLT FOR FRONT COVER	FDB128	EA	150
58.	6100040610	STOP PLUNGER	FDB127	EA	2
59.	6100040611	START PLUNGER	FDB126	EA	2
60.	6100045480	RELAY BASE ONLY	SDPA00012F	EA	6

Chunell
10/01/25
Staff Officer (E&M)
Orient Area