

Sr.No	Description & Specifications	Qty.	UOM	Vendor's Compliance (YES/NO)
	REFILLING			
1.	CO2 CARTRIDGE 60 GRAM	50	Nos	
2.	CO2 CARTRIDGE 120 GRAM	10	Nos	
	HYDROULIC TESTING			
3.	CO2 4.5 KG EXTINGUISHERS	20	Nos	
4.	CO2 6.8 KG EXTINGUISHERS	01	No	
5.	CO2 9 KG EXTINGUISHERS	05	Nos	
6.	CO2 22.5 KG EXTINGUISHERS	01	No	
	REFILLING			
7.	CO2 4.5 KG EXTINGUISHERS	20	Nos	
8.	CO2 6.8 KG EXTINGUISHERS	01	No	
9.	CO2 9 KG EXTINGUISHERS	05	Nos	
10.	CO2 22.5 KG EXTINGUISHERS	01	No	
11.	SQUEEZE GRIP CO2 Valve with PIN ISI Maked IS3224	27	Nos	
12.	SAFETY CLIP WITH MS PIN (SPARE)	27	Nos	
	HYDROULIC TESTING			
13.	WATER TYPE FIRE EXTINGUISHERS 09 LTRS.	40	Nos	
14.	M/FOAM TYPE FIRE EXTINGUISHERS 09	30	Nos	
15.	DCP TYPE FIRE EXTINGUISHERS 06 KG	100	Nos	
	HYDROULIC TESTING			
16.	FE 36 FIRE EXTINGUISHERS 02 KG	20	Nos	
	REFILLING			
17.	FE 36 FIRE EXTINGUISHERS 02 KG	20	Nos	

Vendor's Signature

Vendor's Stamp

SPECIFICATION/CONDITIONS FOR REFILLING OF EXTINGUISHERS & CARTRIDGES.

1. All Extinguishers and Cartridges should be pressure tested as per IS.2190 before refilling and Test Certificate should be supplied for each extinguisher mentioning the cylinder No.
2. Certificate of hydraulic testing of petroleum explosive safety organization (PESO) approved test house for each fire extinguishers should be provided.
3. CO₂ Gas refilling of all CO₂ Extinguishers and Cartridges should be as per IS-307 confirming to following parameters:-

Parameters	Specifications
Gas purity	99.99%
Impurities	
Moistures	<10 ppm
Oil Content/THC	<1 ppm
Sulphur Compounds	<1 ppm

4. Painting of CO₂ Extinguisher should be done as per Clause 6 of IS.2878.
5. Spare components replaced should comply with the recommendation laid out in the Clause 3 of IS. 2878
6. For identification of spare components replacement and painting of extinguishers joint inspection shall be done by representatives from the Vendor and the User before dispatching cylinders to the Vendor premises.
7. The vendor should quote separately for the spares to be replaced in the event of requirement.
8. Fire extinguisher will be supplied to vendor in 02 lots.
9. Vendor should depute its representative for joint inspection and lifting the material for refilling within 07 days of furnishing the advance notice and shall return the extinguishers and cartridges after refilling within 15 days.